CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM





LISTING No. 7257-0087:149 Page 1 of 1

CATEGORY: Photoelectric Smoke Detector (Single/Multiple)

LISTEE: BRK Brands, Inc., 3901 W Liberty St Rd. Aurora, IL 60504-8122

Contact: Mark Dippner (630) 851-7330 ext 1422 FAX (630) 851-9309

DESIGN: Models SC7010B and SC7010BV single or multiple station combination photoelectric

> smoke and CO alarm. Intended to be wall or ceiling mounted. Model SC7010BV is equipped with a voice alarm feature. Refer to listee's data sheet for detailed product

description and operational considerations.

RATING: 120 VAC with two AA type batteries, Energizer E91 for battery backup.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and

ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name and/or First Alert, model number, electrical rating, and ETL label.

APPROVAL: Listed as single and/or multiple station photoelectric smoke detectors. Refer to listee's

Installation Instruction Manual for details.

These units can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation

Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition

NOTE: The photoelectric type detectors are generally more effective at detecting slow,

> smoldering fires, which smolder for hours before bursting into flame. Sources of these fires may include cigarettes burning in couches or bedding. The ionization type detectors are generally more effective at detecting fast, flaming fires, which consume combustible materials rapidly and spread quickly. Sources of these fires may include paper burning in

a waste container or a grease fire in the kitchen.

10-10-2007 mt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

JUNE 6, 2008 Date Issued: Listing Expires June 30, 2009

BEN HO, Chief Authorized By:

Fire Engineering Division